

# VOC Content Test Certificate

Thursday October 1<sup>st</sup>, 2009

Supplier: Peerless Jal Pty Ltd (10-12 Raglan Street, Preston Victoria 3072)

Sample Description: Hyshield waterborne acrylic polyurethane finish

Date Tested: September 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings.

Test Data:

**Hyshield**

**134 grams per Litre as VOC content  
of material**



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

**F0909-29**